

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 28.6.24

It is certified that an inspection team headed by DR. Sanjay Bhanuwar
(Name of Officers with designation) from C.M.O. office Prayagraj
(Name of Department/ Office) inspected the Health Department
(Name & Address of the school) on 26.6.24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of one year

Signature with Seal: Ashu Pandey

Name : DR. Ashu Pandey

Designation : मुख्य चिकित्सा अधिकारी
प्रयागराज

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

मुख्य चिकित्सा अधिकारी
Name & Address of the Office/ Department : प्रयागराज

To

Patangali Rishikul
Talimganj Prayagraj

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



कार्यालय महाप्रबन्धक
जलकल विभाग-नगर निगम
प्रयागराज
पत्र संख्या 508/म.प्र.ज.क.वि. 2024
दिनांक 28.06.2024

PRAYAGRAJ JAL KAL VIBHAG NAGAR NIGAM CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2024-06/12

Date: 28.06.2024

DRINKING WATER ANALYSIS REPORT

1	Name & Address	PATANJALI RISHIKUL SCHOOL PRAYAGRAJ. (UP)
2	Sample Collected by	By Party
3	Nature of Sample	Drinking Water
4	Date of Sample Collection	26.06.2024
5	Date of Sample Receiving	26.06.2024
6	Date of Analysis Completed	28.06.2024


S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	
3.	Temperature	°C	30.1	-	
4.	Turbidity	NTU	0.2	5	10
5.	Conductivity at 25°C	µmho/cm	801	-	
CHEMICAL PARAMETERS					
6.	pH	-	6.9	6.5 to 8.5	No Relaxation
7.	Dissolved Solids	mg/L	383	500	2000
8.	Total Alkalinity (as CaCO ₃)	mg/L	97	200	600
9.	Total Hardness (as CaCO ₃)	mg/L	109	200	600
10.	Chlorides (as Cl)	mg/L	124	250	1000
11.	Fluoride (as f)mg/l	mg/L	0.1	1.0	1.5
12.	Nitrate (as NO ₃)	mg/L	0.97	45	100
13.	Iron (Fe)	mg/L	Nil	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
14.	Total Coliform	MPN/100ml	Absent	Absent	-
15.	E. Coli	MPN/100ml	Absent	Absent	-

*Note: The water is suitable for drinking purposes-


Analyst


(Laboratory In-charge)


JE(HQ)


E.E(HO)
अधिसाक्षी अभियन्ता (मुख्यालय)
जलकल विभाग, नगर निगम
प्रयागराज

Note: 1. The above results are related only to the test performed on the sample. 2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing. 3. sample will be destroyed in the after fifteen days from the date of reporting.